Application Note AN-76 Failure Mode and Effect Analysis BridgeSwitch Family



Device information

Please refer to BridgeSwitch data sheet for pin assignment. Refer to Figure 1 for the package information.




Figure 1. Part Under Test.

Test Results Summary Adjacent Pin-to-Pin Short Test

Fault Mode	Operation Condition		Operation Behavior Notes	
	Start-up	During Operation	Start-up	During Operation
XL to IPH short	No failure	No failure	Device switching disabled	Low-side switching is disabled
IPH to SG short	No failure	No failure	normal operation with no IPH signal	normal operation with no IPH signa
BPL to SG short	No failure	No failure	Device non operational	Device switching is disabled device case temperature will rise
BPL to INL short	No failure	Safe failure	Device non operational	Device non-operational, INL pin damaged, INL pin shorted to SG
INL to /INH short	No failure	No failure	Normal Operation	Normal operation
/INH to FAULT short	No failure	No failure	Device switching disabled	Device switching disabled
FAULT to SM short	No failure	No failure	Normal operation	Normal operation
SM to NC short	No failure	No failure	Normal operation	Normal operation
NC to SG short	No failure	No failure	Normal operation	Normal operation
SG to ID short	No failure	No failure	Normal operation	Normal operation
ID to NC short	No failure	No failure	Normal operation	Normal operation
XH to BPH short	Safe failure	Safe failure	Device non-operational, XH pin is damaged safely	Device non-operational, XH pin is damaged safely
BPH to NC short	No failure	No failure	Normal operation	Normal operation
NC to HB short	No failure	No failure	Normal operation	Normal operation

www.power.com June 2018

Pin Open Test

Fault Mode	Operation Condition		Operation Behavior Notes	
	Start-up	During Operation	Start-up	During Operation
XL open	No failure	No failure	Device switching disabled	Device switching disabled
IPH open	No failure	No failure	Normal operation, no IPH feature as expected	Normal operation, no IPH feature as expected
SG open (one at a time)	No failure	No failure	Normal operation	Normal operation
BPL open	No failure	No failure	Device non operational	Device non operational
INL open	No failure	No failure	Device switching disabled, note short-circuit loop is <2 inch length	Device switching disabled, note short-circuit loop is <2 inch length
/INH open	No failure	No failure	Device switching disabled	Device switching disabled
FAULT open	No failure	No failure	Normal operation with no FAULT feature as expected	Normal operation with no FAULT feature as expected
SM open	No failure	No failure	Normal operation with no SM feature as expected	Normal operation with no SM feature as expected
ID open	No failure	No failure	Normal operation, as one of the ID pin configurations	Normal operation, as one of the ID pin configurations
XH Open	No failure	No failure	Device switching disabled	Device switching disabled
BPH open	No failure	No failure	Device switching disabled, note no probe is connected	Device switching disabled, note no probe is connected
LS open	Safe failure	Safe failure	Device non-operational, BPL pin is damaged safely	Device non-operational, BPL pin is damaged safely

Logic Pin Short to Logic Ground (SG Pin)

Fault Mode	Operation Condition		Operation Behavior Notes	
	Start-up	During Operation	Start-up	During Operation
XL to SG short	No failure	No failure	Device switching disabled	Device switching disabled
IPH to SG short	No failure	No failure	Normal operation with no IPH signal	normal operation with no IPH signal
BPL to SG short	No failure	No failure	Device non operational	Device switching is disabled, device case temperature will rise
INL to SG short	No failure	No failure	Device switching disabled, note test with INL / INH tied together	Device switching disabled, note test with INL / INH tied together
/INH to SG short	No failure	No failure	Device switching disabled, note test with INL / INH tied together	Device switching disabled, note test with INL / INH tied together
FAULT to SG short	No failure	No failure	Normal operation with no FAULT feature as expected	Normal operation with no FAULT feature as expected
SM to SG short	No failure	No failure	Normal operation with no SM feature as expected	Normal operation

High-Side Driver Logic Pin Short to Half-Bridge Connection (HB Pin)

	Operation Condition		Operation Behavior Notes	
Fault Mode	Start-up	During Operation	Start-up	During Operation
XH short to HB	No failure	No failure	Device switching disabled	Device switching disabled
BPH to HB short	No failure	No failure	Device switching disabled	Device switching disabled

Revision	Notes	Date
Α	Initial Release.	06/18

For the latest updates, visit our website: www.power.com

Power Integrations reserves the right to make changes to its products at any time to improve reliability or manufacturability. Power Integrations does not assume any liability arising from the use of any device or circuit described herein. POWER INTEGRATIONS MAKES NO WARRANTY HEREIN AND SPECIFICALLY DISCLAIMS ALL WARRANTIES INCLUDING, WITHOUT LIMITATION, THE IMPLIED WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, AND NON-INFRINGEMENT OF THIRD PARTY RIGHTS.

Patent Information

The products and applications illustrated herein (including transformer construction and circuits external to the products) may be covered by one or more U.S. and foreign patents, or potentially by pending U.S. and foreign patent applications assigned to Power Integrations. A complete list of Power Integrations patents may be found at www.power.com. Power Integrations grants its customers a license under certain patent rights as set forth at www.power.com/ip.htm.

Life Support Policy

POWER INTEGRATIONS PRODUCTS ARE NOT AUTHORIZED FOR USE AS CRITICAL COMPONENTS IN LIFE SUPPORT DEVICES OR SYSTEMS WITHOUT THE EXPRESS WRITTEN APPROVAL OF THE PRESIDENT OF POWER INTEGRATIONS. As used herein:

- 1. A Life support device or system is one which, (i) is intended for surgical implant into the body, or (ii) supports or sustains life, and (iii) whose failure to perform, when properly used in accordance with instructions for use, can be reasonably expected to result in significant injury or death to the user.
- 2. A critical component is any component of a life support device or system whose failure to perform can be reasonably expected to cause the failure of the life support device or system, or to affect its safety or effectiveness.

The PI logo, TOPSwitch, TinySwitch, SENZero, SCALE, SCALE-iDriver, SCALE-iFlex, Qspeed, PeakSwitch, LYTSwitch, LinkZero, LinkSwitch, InnoSwitch, HiperFFS, HiperFFS, HiperLCS, DPA-Switch, CAPZero, Clampless, EcoSmart, E-Shield, Filterfuse, FluxLink, StakFET, PI Expert and PI FACTS are trademarks of Power Integrations, Inc. Other trademarks are property of their respective companies. ©2018, Power Integrations, Inc.

Power Integrations Worldwide Sales Support Locations

World Headquarters

5245 Hellyer Avenue San Jose, CA 95138, USA Main: +1-408-414-9200 Customer Service:

Worldwide: +1-65-635-64480 Americas: +1-408-414-9621 e-mail: usasales@power.com

China (Shanghai)

Rm 2410, Charity Plaza, No. 88 North Caoxi Road Shanghai, PRC 200030 Phone: +86-21-6354-6323 e-mail: chinasales@power.com

China (Shenzhen)

17/F, Hivac Building, No. 2, Keji Nan Bangalore-560052 India 8th Road, Nanshan District, Shenzhen, China, 518057 Phone: +86-755-8672-8689 e-mail: chinasales@power.com

Germany (AC-DC/LED Sales) Lindwurmstrasse 114 D-80337 München

Germany

Phone: +49-89-5527-39100 e-mail: eurosales@power.com

Germany (Gate Driver Sales) HellwegForum 1 59469 Ense

Germany

Tel: +49-2938-64-39990

e-mail: igbt-driver.sales@power.com e-mail: japansales@power.com

#1, 14th Main Road Vasanthanagar Phone: +91-80-4113-8020 e-mail: indiasales@power.com

Italy

Via Milanese 20, 3rd. Fl. 20099 Sesto San Giovanni (MI) Italy Phone: +39-024-550-8701 e-mail: eurosales@power.com

Yusen Shin-Yokohama 1-chome Bldg. Taiwan 1-7-9, Shin-Yokohama, Kohoku-ku Yokohama-shi, Kanagawa 222-0033 Japan Phone: +81-45-471-1021

RM 602, 6FL Korea City Air Terminal B/D, 159-6 Samsung-Dong, Kangnam-Gu, Seoul, 135-728, Korea Phone: +82-2-2016-6610

e-mail: koreasales@power.com

Singapore

51 Newton Road #19-01/05 Goldhill Plaza Singapore, 308900 Phone: +65-6358-2160

e-mail: singaporesales@power.com

5F, No. 318, Nei Hu Rd., Sec. 1 Nei Hu Dist.

Taipei 11493, Taiwan R.O.C. Phone: +886-2-2659-4570 e-mail: taiwansales@power.com

UK

Building 5, Suite 21 The Westbrook Centre Milton Road Cambridge CB4 1YG

Phone: +44 (0) 7823-557484 e-mail: eurosales@power.com